



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J0441

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Wilson

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 10/02/2020
 Reported: 10/27/2020

Analytical Testing Parameters

Client Sample ID:	67	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/01/2020 7:15
Lab Sample ID:	J0J0441-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2146	LLW

Client Sample ID:	78	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/01/2020 7:30
Lab Sample ID:	J0J0441-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2151	LLW

Client Sample ID:	70	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/01/2020 7:15
Lab Sample ID:	J0J0441-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2153	LLW

Client Sample ID:	65	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/01/2020 7:12
Lab Sample ID:	J0J0441-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2155	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-05		Collection Date: 10/01/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2157	LLW

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-06		Collection Date: 10/01/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0120	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2159	LLW

Client Sample ID: 79	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-07		Collection Date: 10/01/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2205	LLW

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-08		Collection Date: 10/01/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0056	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2206	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-09		Collection Date: 10/01/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0354	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2208	LLW

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-10		Collection Date: 10/01/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2210	LLW

Client Sample ID: 60	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-11		Collection Date: 10/01/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2212	LLW

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-12		Collection Date: 10/01/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2216	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-13		Collection Date: 10/01/2020 6:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2218	LLW

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-14		Collection Date: 10/01/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0020	mg/L	D	10/12/20 1514	10/15/20 1103	LLW

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-15		Collection Date: 10/01/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2222	LLW

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-16		Collection Date: 10/01/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0020	mg/L	D	10/12/20 1514	10/15/20 1110	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-17		Collection Date: 10/01/2020 8:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2229	LLW

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-18		Collection Date: 10/01/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0190	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2231	LLW

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-19		Collection Date: 10/01/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0258	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2233	LLW

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-20		Collection Date: 10/01/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		10/12/20 1514	10/12/20 2235	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-21		Collection Date: 10/01/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0326	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2245	LLW

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-22		Collection Date: 10/01/2020 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2250	LLW

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-23		Collection Date: 10/01/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0135	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2252	LLW

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-24		Collection Date: 10/01/2020 6:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2254	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-25		Collection Date: 10/01/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2256	LLW

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-26		Collection Date: 10/01/2020 6:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2258	LLW

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-27		Collection Date: 10/01/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.015 AL	0.0010	mg/L		10/13/20 1345	10/14/20 0917	DLO

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-28		Collection Date: 10/01/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0130	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2304	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 16	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-29		Collection Date: 10/01/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2306	LLW

Client Sample ID: 71	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-30		Collection Date: 10/01/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2308	LLW

Client Sample ID: 74	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-31		Collection Date: 10/01/2020 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2310	LLW

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-32		Collection Date: 10/01/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0316	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2313	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-33		Collection Date: 10/01/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0096	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2315	LLW

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-34		Collection Date: 10/01/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0087	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2317	LLW

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-35		Collection Date: 10/01/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0367	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2319	LLW

Client Sample ID: 59	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-36		Collection Date: 10/01/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2321	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-37		Collection Date: 10/01/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0381	0.015 AL	0.0102	mg/L	D	10/12/20 1516	10/15/20 1119	LLW

Client Sample ID: 64	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-38		Collection Date: 10/01/2020 7:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2329	LLW

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-39		Collection Date: 10/01/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0141	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2331	LLW

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-40		Collection Date: 10/01/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2333	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-41		Collection Date: 10/01/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0333	0.015 AL	0.0010	mg/L		10/12/20 1516	10/12/20 2335	LLW

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-42		Collection Date: 10/01/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0097	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1305	LLW

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-43		Collection Date: 10/01/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1310	LLW

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-44		Collection Date: 10/01/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0183	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1312	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-45		Collection Date: 10/01/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1314	LLW

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-46		Collection Date: 10/01/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1315	LLW

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-47		Collection Date: 10/01/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1317	LLW

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-48		Collection Date: 10/01/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1323	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-49		Collection Date: 10/01/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0121	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1325	LLW

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-50		Collection Date: 10/01/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0162	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1326	LLW

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-51		Collection Date: 10/01/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1328	LLW

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-52		Collection Date: 10/01/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0148	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1330	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-53		Collection Date: 10/01/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0131	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1334	LLW

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-54		Collection Date: 10/01/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1336	LLW

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-55		Collection Date: 10/01/2020 6:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1337	LLW

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-56		Collection Date: 10/01/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1339	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-57		Collection Date: 10/01/2020 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0092	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1345	LLW

Client Sample ID: 81	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-58		Collection Date: 10/01/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0240	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1347	LLW

Client Sample ID: 12	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-59		Collection Date: 10/01/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0084	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1348	LLW

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-60		Collection Date: 10/01/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0051	0.015 AL	0.0051	mg/L	D	10/12/20 1518	10/15/20 1124	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-61		Collection Date: 10/01/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0085	0.015 AL	0.0010	mg/L		10/12/20 1518	10/14/20 1352	LLW

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-62		Collection Date: 10/01/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		10/13/20 1519	10/13/20 1859	LLW

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-63		Collection Date: 10/01/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0103	0.015 AL	0.0010	mg/L		10/13/20 1519	10/13/20 1901	LLW

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0441-64		Collection Date: 10/01/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0157	0.015 AL	0.0010	mg/L		10/13/20 1519	10/13/20 1903	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0441

Client Sample ID: 75	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/01/2020 7:20
Lab Sample ID: J0J0441-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0068	0.015 AL	0.0010	mg/L		10/13/20 1519	10/13/20 1904	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 10/27/2020 13:21

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY00935


WILSON

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bus. Days:	2-5 3-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		

Sample Information			Matrix		
Description/Location	Date	Time	Type	Type	
67	10/1	715	DW		
78		730			
90		715			
65		712			
73		712			
57		706			
79		638			
62		718			
42		648			
72		718			
60		710			
26		623			
27		623			
61		710			
63		712			
62		710			
26		723			
58		707			
82		707			
28		630			

Total Lead (EPA 200.8)		Analysis Requested	
Plastic			
250 ml			
HNO3			
1	Number of Containers for Analysis Requested		

efferson-Lewis-Hamilton-Herkimer-Oneida BOCE
PM: Shannon Weeks



Sampled:	<i>[Signature]</i>	Date/Time	10/1/20	Comments
Received:	<i>[Signature]</i>	Date/Time	10-2-20	10-39/500
Received:	<i>[Signature]</i>	Date/Time		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Wilson

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: Lead Testing
 Quote ID: PO#:
 Rush TAT Bus. Days: 2-5 3-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes
 Billing/Invoice: rfilley@boces.com, fhauck@boces.com, lshaw@boces.com

Analysis Requested
 Total Lead (EPA 200.8)
 Plastic
 250 ml
 HNO3
 Matrix Type: DW

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: YES NO
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material
 Container Size (in MI)
 Preservative

Sample Information		Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Matrix Type	
29	10/1	6:30	DW	
50		6:55		
41		7:45		
45		6:50		
40		6:50		
48		6:52		
49		6:55		
51		7:00		
35		6:35		
33		6:32		
32		6:30		
11		6:15		
36		6:35		
37		6:40		
2		6:01		
52		6:00		
81		6:39		
12		6:15		
38		6:45		

J 0 J 0 4 4 1
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Print Name and Company
[Signature]
 Date/Time: 10/1/2020
 Comments:

Sampled: Received: Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

