



# RESULTS OF WATER TESTING FOR LEAD CONTENT

Roger L. CayCe, Deputy Superintendent of Operations

December 8, 2017



## 2017-2018 WATER TESTING RESULTS

- Water sources at all active school buildings were initially screened for lead content as of August 2016.

<b>Initial Test Results Indicated</b>	
<b>Number of active school buildings</b>	<b>72</b>
<b>Total number of water sources sampled</b>	<b>797</b>
<b>Sources reported at 20 ppb or greater</b>	<b>45</b>
<b>Sources reported at 10 ppb to 19.9 ppb</b>	<b>43</b>

# 2017-2018 WATER TESTING RESULTS

- Conducted lead testing of (44) drinking fountains and (31) sink faucets that were previously identified having lead concerns. After receiving results, there were (3) drinking fountains and (1) sink faucet that failed. All repairs were made and the District is now compliant.
- Annual retesting of (44) drinking fountains and (31) sink faucets will continue in 2018-2019 school year.
- All buildings in the District will have to be retested for lead every three years. The next scheduled (3) year retest will occur in 2019-2020 school year.

## 88 Total Water Sources

	Fountains	Sinks
<b>Total (Original Actionable Items)</b>	<b>48</b>	<b>40</b>
<b>Passed</b>	<b>44</b>	<b>31</b>
<b>Abandoned (During 2016-2017 School Year)</b>	<b>4</b>	<b>9</b>

# Questions